



Since-1999

GSTIN- 23AGQPD0362E1ZV

# THE NEW KNOT SALES AND MARKETING

209, LIG-II, Indira Nagar, Agar Road, Ujjain (M.P.) 456001

Ph. 0734- 2580386 Mob. 9826088832 ,E mail : ujnksm@rediffmail.com



An  Registered & ISO 9001:2015 Certified Firm

## CERTIFICATE

NKSM/2024/1164

- Client Name : Jolly Memorial mission School
- Address : Ora Park, Near Sethi Nagar, Ujjain (M.P.)
- Contact No. : 8959399494
- Certificate No. : NKSM/2024/1164
- Invoice No. : 499, Dated 03/06/2024
- Certificate Validity : 04/06/2024 to 03/06/2025

This Is To Certify That Following Types Of Fire Extinguishers, Which Are Installed At The Premises Of Our Client, Are Sufficient For Fire Safety.

All These Fire Extinguishers Have Been Supplied, Hydro Tested, Inspected And Our Technician Has Carried Out Refilling.

No.	Type of fire extinguishers	Capacity	IS: Specification	MFG Year.	Hpt. Date		Quantity
					Done	Due	
01.	ABC Stored Pressure	06 kgs.	IS:15683	2022	2022	2025	01 No.
02.	ABC Stored Pressure	06 kgs.	IS:15683	2022	2022	2025	01 No.
03.	ABC Stored Pressure	06 kgs.	IS:15683	2022	2022	2025	01 No.
04.	ABC Stored Pressure	06 kgs.	IS:15683	2022	2022	2025	01 No.
05.	ABC Stored Pressure	06 kgs.	IS:15683	2022	2022	2025	01 No.
06.	ABC Stored Pressure	06 kgs.	IS:15683	2022	2022	2025	01 No.
07.	ABC Stored Pressure	04kgs.	IS:15683	2022	2022	2025	01 No.
08.	ABC Stored Pressure	04kgs.	IS:15683	2022	2022	2025	01 No.
09.	ABC Stored Pressure	04kgs.	IS:15683	2022	2022	2025	01 No.
10.	ABC Stored Pressure	04kgs.	IS:15683	2022	2022	2025	01 No.
11.	ABC Stored Pressure	04kgs.	IS:15683	2022	2022	2025	01 No.
12.	Carbon Dioxide	04.5 Kgs.	IS:15683	2022	2022	2027	01 No.
Total							12 Units

Practical demonstration on the fire extinguishing by ABC Stored Pressure type fire extinguishers was performed to make staff understand capabilities of the extinguishers.

Hence we certify that all fire extinguishers are perfect and adequate for operation.



Vishwas Dubey

For: The New Knot Sales And Marketing,  
Ujjain (M.P.)

AIM

ZERØ INCIDENT → In 2024